

Government of Andhra Pradesh
A.P. State Disaster Response and Fire Services Department

Periodical Renewal Fire Certificate

From:
District Disaster Response & Fire Officer
Andhra Pradesh, East Godavari

To:
District Educational Officer, East Godavari
District, Rajamahendravaram ,

File No: 32365/EGV/DFO/2026, Date:11/06/2026
Occupancy NOC RC Number: 24896/EGV/MSB/2025

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of SANKALP EDUCATIONAL SOCIETY,INTERNATIONAL DELHI PUBLIC SCHOOL, represented by Smt M. SUKANYA VANI, D.No:11-06-19 & 11-06-20 , Duddupudi Gardens, Vemuluru Road,Kovvuru - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
 2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.02-05-2023.
 3. This Office NOC for Occupancy Rc No. 24896/EGV/MSB/2025, Dt.05/02/2025
 4. Renewal NOC For Occupancy 24896/EGV/MSB/2025, Dt.05/02/2025
 5. Online Application for Renewal NOC of Smt M. SUKANYA VANI, D.No:11-06-19 & 11-06-20 , Duddupudi Gardens, Vemuluru Road,Kovvuru - Inspection report called for Regarding.
 6. Online Inspection Report submitted by Officers of this Department on 10-06-2026.

- x -

The Management of SANKALP EDUCATIONAL SOCIETY,INTERNATIONAL DELHI PUBLIC SCHOOL, represented by Smt M. SUKANYA VANI, D.No:11-06-19 & 11-06-20 , Duddupudi Gardens, Vemuluru Road,Kovvuru has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.37308/- vide challan No. 10047081242026, Dated 05/06/2026 at ONLINE, ONLINE.

Block-1 ,Block-III ,Block-II

1. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023
2. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate for vide reference 4th cited to the existing Non Multi Storeyed Building.
3. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate Smt M. SUKANYA VANI D.No:11-06-19 & 11-06-20 , Duddupudi Gardens, Vemuluru Road,Kovvuru, subject to the following conditions.

SI As Builder

- 1 All the fire protection arrangements shall be maintained in good condition as seen during inspection.
- 2 Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.
- 3 Addition / alteration, if any in the building may be verified by building authority.

As Occupant

- 1 All the escape/exit routes shall not be kept locked/blocked or encroached
- 2 All occupants shall be trained to operate the fire safety equipments during emergency.
- 3 Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.

As Security Personnel

- 1 All the occupants must know the correct method of operation of the fire fighting system installed.
- 2 Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
- 3 All security personnel shall be trained to operate the fire safety equipments during emergency.



Manager
International Delhi Public School
Kovvur


Principal
International Delhi Public School
Kovvur

4

This is Only for Fire Safety Point of View

Raise the alarm if the fire cannot be controlled, Evacuate the area completely at once with nearest safe exit.

Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

4 This Periodical Renewal Fire Certificate is valid from 11/06/2026 to 10/06/2031.

5. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire safety Act 1999 and Rules, 2006.

6. Challan Info:

Challan Number
10047081242026

Challan Date
2026-06-05

Challan Amount
37308

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended to by the management.

the inspection committee inspected the said premises and submitted a report stating that there are three blocks in the campus. Out of these, two blocks consist of Ground Floor + 1 Upper Floor, and the remaining block consists of Ground Floor only. The management has obtained a No Objection Certificate for Occupancy vide File No. 24896/EGV/MSB/2025, dated 05.02.2025. The management has remitted the Fire Precautionary Fee vide CFMS Challan No. 10047081242026, dated 05.06.2026, for an amount of Rs. 37,308/- towards five (05) years. The management has also submitted an affidavit undertaking to provide the required fire-fighting equipment within three (03) months. the inspection committee tested the existing fire-fighting equipment, and its working condition was found to be satisfactory. Hence, the inspection committee recommended to issue the Renewal No Objection Certificate. Based on the inspection committee report the renewal of NOC is Approved.

It shall be the responsibility of the Management to ensure that the installed fire-fighting equipment is maintained in working condition 24/7. In case of failure, the Management/Occupier/Owner will be held Liable under the relevant laws in force.

"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సुरక్షిత పాఠశాలలు, సురక్షిత మైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."



Your Sincerely,

[Signature]
11/6/26

District Disaster Response & Fire Officer,
East Godavari District

In case of emergency, please call 101 or 08813-231101 or 9963726417

Copy to Management Smt M. SUKANYA VANI, Smt M. SUKANYA VANI, SANKALP EDUCATIONAL SOCIETY, INTERNATIONAL DELHI PUBLIC SCHOOL

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned

Manager

International Delhi Public School
Kovvur

[Signature]
Principal

International Delhi Public School
Kovvur